

EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Decree no. 2016-0000038870

Certificate no. : NL17-400-1002-048-15 Revision no.: 1

Description of the product : Control boards for electric and hydraulic lifts with monitoring circuit for safety chain and door bridging circuit, also applied for monitoring, detection and activation of UCMP and ACOP

Trademark, type : Arkel, ARL-700 lift control and interface PCB's:
ARL-700 CPU_V1.xx, ARL-700 GLB_V1.xx, HSR V1.xx,
KBK-12 V1.xx, KBK-13 V1.xx, KDB V1.xx and IBC-S V1.xx

Name and address of the manufacturer : Arkel Elektrik Elektronik San. ve Tic. As.
Serifali Mah. Turker Cad. No:51 34775
Umraniye, Istanbul, Turkey

Name and address of the certificate holder : Arkel Elektrik Elektronik San. ve Tic. As.
Serifali Mah. Turker Cad. No:51 34775
Umraniye, Istanbul, Turkey

Certificate issued on the following requirements : Lifts Directive 2014/33/EU

Certificate based on the following standard : EN 81-20:2014 clause 5.6.7.3, 5.6.7.7, 5.6.7.9, 5.6.6.2, 5.11.1.1 and 5.11.2.1.2,
EN 81-50:2014 clause 5.8 and 5.15

Test laboratory : None

Date and number of the laboratory report : None

Date of EU-type examination : June – August 2017
Rev.1; December 6, 2017

Additional document with this certificate : Report belonging to the EU-type examination certificate no.: NL17-400-1002-048-15 rev.1


Additional remarks : See report

Conclusion : The PCB's ARL-700 CPU_V1.xx, ARL-700 GLB_V1.xx, HSR V1.xx, KBK-12 V1.xx, KBK-13 V1.xx, KDB V1.xx and IBC-S V1.xx meet the requirements referred to in this certificate taking into account any additional remarks mentioned above.

Amsterdam

Date : 06-12-2017
Valid until : 31-08-2022


ing. P.J. Peeters
Manager


Certification decision by